>Knightsbridge

DISMANTLING PROCEDURE

This product should be dismantled for disposal when it reaches the end of its life. Ensure that the electrical supply is disconnected before removal from the installation. Consult a qualified electrician if in any doubt.

Product type:	Low Bay
Product codes:	LWBxxx
Dismantling procedure:	

- 1. Remove terminal housing cover
- 2. Remove metal end caps, and separate the LED strip housings from the main body
- 3. Slide polycarbonate diffusers out from the LED strip housings
- Remove driver, emergency inverter (if fitted), and battery (if fitted) from luminaire
- 5. Remove terminal block and all internal wiring

Recycling material:	
Polycarbonate diffusers	Plastic
LED strip modules in metal housing	Electrical goods
LED driver	
Emergency inverter	
Terminal block	
Battery	Batteries
Luminaire housing	Metal
Screws	

Advice from local recycling facilities should be sought as to specific types of waste which may be accepted.



